

FLOOR MOUNTED CONDENSER UNITS

REFRIGERANT PIPEWORK ALLOW FOR 200mmWx100mmH

CEILING MOUNTED CASSETTE TYPE FCU ALLOW 300 mm HIGH IN CEILING VOID (TYPICAL UNLESS OTHERWISE SPECIFIED)

0.2 m2 AREA WEATHER PROOF EXHAUST LOUVRE

0.05 m2 AREA WEATHER PROOF EXHAUST LOUVRE

SUPPLY AND INSTALL QASAIR 1200HL-2 RANGE HOOD TO EXHAUST THROUGH 325x245 QASAIR BD/VV-H-1 WALL VENTS. COMPLETE WITH HORIZONTAL WALL VENT COVERS WVC - H - 1

150x150 WEATHER PROOF EXHAUST LOUVRE.

ALLOW 600x500 CLEAR SPACE FOR DUCTWORK (400x300 + INSULATION)

RETURN AIR GRILLE IN VERTICAL FACE, 300x1050 BAR GRILLE

0.2 m2 AREA WEATHER PROOF INTAKE LOUVRE

CONDENSATE WATER BY HYDRAULIC ENGINEER. TYPICAL

4 NO. CIRCULAR JET DIFFUSER (250mm DIAMETER) 135 L/S EACH.

500x500 TOILET EXHAUST FAN DUTY 310 L/S

0.3 m2 AREA WEATHER PROOF EXHAUST LOUVRE

1	FOR CONSTRUCTION	FC	JH	16.05.16
0	FOR CONSTRUCTION	IM	JH	16.07.15
E	TENDER	HCM	JH	23.03.15
D	95% DOCUMENTATION	HCM	JH	12.02.15
C	95% DOCUMENTATION	HCM	JH	11.02.15
B	95% DOCUMENTATION	FIC	JH	19.12.14
A	PRELIMINARY	FIC	JH	15.12.14
REV.	DESCRIPTION	DRAWN	APP'D	DATE

CLIENT :
 Leichhardt Municipal Council
 7-15 Wetherill Street
 LEICHHARDT NSW 2040

ARCHITECT :
 Dillon & Savage Architects
 40 Quinton Rd, Manly, 2095
 Phone: (02) 9977 3714 Fax: (02) 9977 8215
 email: dsarche@bigpond.net.au

WOOD & GRIEVE ENGINEERS
 Wood & Griev Engineers Ltd
 A.C.N. 137 699 609
 Level 6, Building 5,
 207 Pacific Highway, St Leonards
 New South Wales 2005
 Phone: 02 8484 7000
 Fax: 02 8484 7100
 Email: sydney@wge.com.au
 Web: www.wge.com.au


PROJECT:
 LEICHHARDT PARK CHILD CARE

TITLE:
 MECHANICAL SERVICES
 FLOOR PLAN LAYOUT

FOR CONSTRUCTION

DESIGNED : FIC	VERIFIED :	---
DRAWN : FIC	APPROVED FOR TENDER :	---
SCALE : 1:100@A1	APPROVED FOR CONSTRUCTION :	---

CAD FILE: 26687M-100.dwg PLOT DATE/TIME: 16.05.16 01:32 PM



PROJECT No. 26687-SYD	DRAWING No. M-100	REVISION 1
---------------------------------	-----------------------------	----------------------